

Continuous
No. 4 Bar (Minimum)
as Required

Center Distance, A,
Not Required Stirrups

Lintel
Reinforcement
as Required

Side
bars
required
withing
24"
from
opening

2' or less
No header or
side rebar
required

Minimum 8"

A

$l < 2'$
(0.61mm)

24"
(0.61mm)

$l \geq 2' < (0.61 \text{ mm})$

24"
(0.61mm)

NO. 4 Bar

Opening Reinforcement
as Required

Wall Reinforcement
as Required
See engineering



REINFORCEMENT OF OPENINGS

DATE/REV 11-17-09

SCALE NTS

DETAIL SHEET

NOTES

9705 N. BROADWAY EXTENSION, SUITE 200, OKLAHOMA CITY, OK 73114
OFFICE: 405-840-3386 | TOLL FREE: 866-222-2575 | FAX: 831-597-0792
BUILDBLOCK.COM

CONSTRUCTION SHALL BE IN ACCORDANCE WITH ALL APPLICABLE
LOCAL AND NATIONAL CODES. ALL DRAWINGS ARE SUBJECT TO
CHANGE WITHOUT NOTICE.

30A